



# Attestation of Conformity

No. 2017-778

## Cables for use in construction works Reaction to fire class E<sub>ca</sub>

### Company

Keynet Sistemas Profesionales S.L.  
C/ Alcalde Fatás  
Naves 17-19  
50410 Cuarte  
Zaragoza  
Spain

### Product description

Screened communication cable (S/FTP) with solid conductors  
4 twisted pairs, LSZH jacket

### Product identification

S/FTP CAT6A 4P 23AWG LSZH  
Part no. TD-630ASF-L

### Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2014

### Reaction to fire classification

Class E<sub>ca</sub>

### Technical report

DELTA-T733349-01, DANAK-19/18336

### EC Cabling product ID

6448

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 15 September 2017

Lars Lindskov Pedersen  
Test Manager

Dennis Andersen  
Head of Department

---

### DELTA – a part of FORCE Technology

Venlighedsvej 4      Tel. +45 72 19 40 00  
2970 Hørsholm      Fax +45 72 19 40 01  
Denmark      [www.madebydelta.com/cable](http://www.madebydelta.com/cable)